



Recharger Chamber Specification Information

	Contactor® Field Drain™ Model C-4	Contactor® Model EZ-24	Contactor® Model 100	Contactor® Model 125	Recharger® Model 150	Recharger® Model 180	Recharger® Model 280	Recharger® Model 330	Recharger® Model 330XL	Recharger® Model V8 I
Length	8.50'	8.50'	8.00'	7.50'	8.50'	7.33'	8.00'	7.50'	8.5'	8.00'
Installed Length	8.00'	8.00'	7.50'	6.25'	7.50'	6.33'	7.00'	6.25'	7.00'	7.50'
Length Adjustment	.50'	.50'	.50'	1.25'	1.00'	1.00'	1.00'	1.25'	1.50'	.50'
Width	48"	16"	36"	30"	33"	36"	47"	52"	52"	54"
Height	8.5"	12"	12.5"	18"	18.50"	20.50"	26.50"	30.50"	30.5	34"
Storage Capacity of Model R	107.57 gal.	52.06 gal.	111.61 gal.	124.55 gal.	168.50 gal.	188.90 gal.	363.81 gal.	418.50 gal.	474.31	N/A
Storage Capacity	1.692 ft ³ / ft	.819 ft ³ / ft	1.866 ft ³ / ft	2.220 ft ³ / ft	2.650 ft ³ / ft	3.445 ft ³ / ft	6.079 ft ³ / ft	7.459 ft ³ / ft	7.459 ft ³ / ft	8.933 ft ³ / ft
Chamber Storage Capacity	13.53 ft ³ / unit	6.55 ft ³ / unit	13.99 ft ³ / unit	13.87 ft ³ / unit	19.87 ft ³ / unit	21.80 ft ³ / unit	42.55 ft ³ / unit	46.61 ft ³ / unit	52.21 ft ³ / unit	66.99 ft ³ / unit
Min. Storage Capacity with Stone¹	29.99 ft ³ / unit	14.06 ft ³ / unit	26.77 ft ³ / unit	29.16 ft ³ / unit	36.71 ft ³ / unit	35.37 ft ³ / unit	64.46 ft ³ / unit	70.77 ft ³ / unit	79.26 ft ³ / unit	97.72 ft ³ / unit
Max. Inlet Opening²	4.5" dia.	6" dia.	10" dia.	12" dia.	12" dia.	15" dia.	18" dia.	24" dia.	24" dia.	24" dia.

Notes:

- a. Recharger 150 and Recharger V8 are only available in Heavy Duty.
- b. Recharger 180, 280 & 330 are available in Standard Duty or Heavy Duty.
- c. Heavy Duty models are designated by adding "HD" after the model number. (ie Recharger 180HD)

Footnotes:

¹ Based on installed length. Stone void is calculated at 40%. Includes 6" stone base. 6" above chamber crown and stone around units based on typical minimum center to center spacing

² Based on HDPE pipe.

The Above Information Compliments of Your Local Cultec Representative:
East Coast Associates, Inc.
Roseland • NJ
Phone: 973-228-3448 • Fax: 973-228-5747
Contact: Mark Sisco • Email: msisco@estcst.com